

A50 Safety System

WHAT TO DO IN CASE OF ALARM

CHECK THE TABLE BELOW TO DETERMINE THE COURSE OF ACTION

DISPLAY	CONDITION	ACTION
OK and Alarm 1 lights are flashing slowly	Time Weighted Average Alarm (TWA)	<p>Open exterior doors and windows to ventilate the area</p> <p>Look for the leak and remedy.</p> <p>The TWA alarm will clear when the average CO₂ levels are under 5000PPM over and 8 hour period</p> <p>If TWA does not resolve in a 24 hour period, contact service at</p> <p>----- *</p>
Alarm 1 light is flashing and the horn is sounding	Warning Alarm	<p>Open exterior doors and windows to ventilate the area</p> <p>Shut off the gas supply</p> <p>Look for the leak and remedy</p> <p>If the reading does not return to normal levels after one hour call service at</p> <p>----- *</p>
Alarm 1 and 2 lights are flashing and the horn is sounding faster	Danger Alarm	<p>DO NOT ENTER the risk zone!</p> <p>Evacuate the area</p> <p>Call service at</p> <p>----- *</p> <p>Ensure, to the extent possible, that there is ventilation from the outside</p>
OK light is continuously on / Fault light is on and the horn is sounding very fast	Fault	<p>Call service at</p> <p>----- *</p>

*Complete these boxes before attaching.