



Central Unit configuration settings

The following table shows the configurable items that can be changed in the Central Unit software menus

NOTE: PLEASE MAKE A NOTE OF THE NEW CONFIGURATION SETTING IN THE NEW SETTING COLUMN NEXT TO EACH CONFIGURATION OPTION.

Item	Default setting	New setting	Comment
Global Evacuation mode	Evacuate		Each alarm has its own evacuation mode.
Number of attached sensor	2		A COMMS fault will occur if the correct number of sensors have not attached.
Relay fail-safe mode	Fail-safe		Default applies to both relays, but each can be set independently