



# WARNING

**It is ONLY safe to enter if the green light is flashing slowly**

**If any of the alarms are activated or activate whilst you are in the room you must carry out the following:**

**Green light is continuously on:**

**Call Service Engineer**

**ALARM 1: Light on and horn sounding**

**Ventilate the area until alarm light goes out, source the leak and repair**

**ALARM 1 and 2:**

**Lights are on and horn is sounding faster**

**The CO2 levels have increased to dangerous levels. Vacate the area, do not enter. Contact your local fire brigade**

**Complete this box before attaching inside and outside the gas storage area**

**Contact:**

**Tel:**