



WARNING

It is ONLY safe to enter if the green light is flashing slowly

If any of the alarms are activated or activate whilst you are in the room you must carry out the following:

Green light is continuously on:

Call Service Engineer

ALARM 1: Light on and horn sounding

Ventilate the area until alarm light goes out, source the leak and repair

ALARM 1 and 2:

Lights are on and horn is sounding faster

The CO2 levels have increased to dangerous levels. Vacate the area, do not enter. Contact your local fire department

Complete this box before attaching inside and outside the gas storage area

Contact:

Tel: